



**Sublimity Fire District
Safety Committee Minutes
October 5, 2006**

Call to order: Geoff McFarland called the meeting to order at 4:00 p.m.

Members present: Tim Gardner, Angela Hargin, Amy Manning, Geoff McFarland

Members absent: None

Additions/Deletions to Agenda: None

Reading of Minutes: The minutes from September 13, 2006, were approved.

Old Business: Pacific Coast Electric will be coming to hardwire in the pop machine and add a light to the new weight room.

The committee discussed having extra air packs and sets of turnouts at Station 52.

Angela put together the MSDS binders for both stations. The group commended her on a job well done.

New Business: The committee inspected Station 52 and Station 51. Issues from Station 52: hose racks are in the way; old oxygen bottles need to be discarded, new ones should be secured; large metal shelf in back corner needs to be secured; need a metal rag container; need glove holders in rigs.

Issues from Station 51: problems with BBQ dials; hint of natural gas smell even when burners/oven are off; half the burners don't work; hot water heater in mezzanine covered with wood; fire extinguishers need to be inspected/maintained; stuff on top of turnout racks should be moved; outlet in bay near hose needs to be GFI; remote nozzle doesn't stay put on E-51.

Adjourn: Meeting adjourned at 5:02 p.m.

Next meeting: The next meeting was scheduled for Thursday, November 9, at 5:00 p.m.

Submitted by Amy Manning

Accepted by Geoff McFarland